

Pre-completion check

Plot 14, 14 Foxglove Rise, Chiswell Green, AL2 3EX

Developer	Prepared by (buyer)
Example Developer Homes	A. Sample
Checked on	Report generated
22 September 2026	22 Sept 2026, 23:20
Report reference	Content fingerprint
EY-00QCJ3	EDAB4B03

5 items to put right, including 1 flagged as safety-related.

0	2	3	2
Emergency	Defects	Snags	Photographs

2 items ask the developer to investigate the cause. The buyer has not diagnosed these.

PLEASE LOOK AT THESE FIRST

SAFETY

Ref 4 Uneven edge or step that could catch a foot · Hallway

I would be grateful if you could confirm in writing that you have received this report, and tell me when each item will be put right.

About this report

This report was written by the buyer of the home, using HOME by EYASTRA, a guided visual check. It records what the buyer could see and try during their visit. It is not a survey and it is not a snagging inspection by a qualified professional, and it does not replace the developer's own inspections. Where the cause of a problem is not clear, the report asks for it to be investigated and does not suggest a cause.

CONDITIONS ON THE DAY

Light	Good daylight
Weather	Dry
Heating	On
Electricity	On
Water	On
Cleanliness	Cleaned

WHAT THIS CHECK COULD NOT ESTABLISH

- Measured tolerances, such as skirting gaps, handrail clearances, fire-door gap sizes, the height of the damp-proof course, or the size of chips and cracks.
- Testing every socket with a socket tester (the guided check uses a lamp or charger that is known to work).
- Inspection of loft timbers, roof felt and cabling, or a close inspection of roof coverings.
- Lifting drain covers, or flushing and inspecting drains and chambers.
- Checking gutters and downpipes for leaks in dry weather.
- Any part of the home that is not safely accessible, and, in apartments, communal plant rooms, risers, lift rooms and roof spaces.
- Structural, ground, damp or moisture surveying, and any diagnosis of causes. Where a cause is unclear the report asks the developer to investigate rather than stating one.

WHAT THE PRIORITIES MEAN

EMERGENCY	An immediate threat to safety, security, health or wellbeing, such as a lock that will not secure an external door or a water leak that cannot be contained.
DEFECT	Something that affects how the home works or is used, or could lead to further damage.
SNAG	A minor or cosmetic matter that does not affect how the home works.

Priorities are the buyer's own suggestion, using the words commonly used in the industry. The developer's customer-care team may classify an item differently, and is asked to explain if it does.

Who is asked to act

The items are grouped here by the kind of work involved, so they can be passed to the right people. "To be assessed" means the buyer could not tell which trade is responsible.

Carpentry and joinery	1 item	Ref 5
Plastering and decorating	1 item	Ref 1
Tiling and sealant	1 item	Ref 3
Flooring	1 item	Ref 4
Groundworks, paving and landscaping	1 item	Ref 2

Items to put right

Each item says what was seen, what is being asked for, and who should do it. Photographs are shown with the time they were taken.

Hallway

2 items

Ref 4

Uneven edge or step that could catch a foot

Threshold into the kitchen

WHAT WAS SEEN

There is an uneven edge or change in level in the floor that could catch a foot.

REQUESTED ACTION · FLOORING

Adjust the transition so it is even and safe.

Status: Open · Recorded 22 Sept 2026, 23:20

SAFETY

DEFECT

Ref 5

Door stop missing or badly placed

Cupboard door under the stairs

WHAT WAS SEEN

There is no effective door stop, or it is placed so the door or its handle can strike the wall or another fitting.

REQUESTED ACTION · CARPENTRY AND JOINERY

Fit or reposition a door stop to protect the wall and fittings.

Status: Open · Recorded 22 Sept 2026, 23:20

SNAG

Living room

1 item

Ref 1

CAUSE NOT DIAGNOSED

SNAG

Crack

Walls or ceiling · On the chimney-breast wall, above the fireplace

WHAT WAS SEEN

A wall or ceiling shows a crack. Its cause cannot be judged from a visual check.

REQUESTED ACTION · PLASTERING AND DECORATING

Inspect the crack, advise on its likely cause and repair it, making good the decoration.

Status: Open · Recorded 22 Sept 2026, 23:20



Photo 1 · 22 Sept 2026, 23:20

Kitchen

1 item

Ref 3

SNAG

Sealant missing or messy

Worktop · Left-hand run, where the worktop meets the wall

WHAT WAS SEEN

The sealant around the worktop is missing, gappy or untidy.

REQUESTED ACTION · TILING AND SEALANT

Clean out and reseal to give a continuous, neat finish.

Status: Open · Recorded 22 Sept 2026, 23:20

Outside: around the home

1 item

Ref 2

CAUSE NOT DIAGNOSED

DEFECT

Water lies, or falls towards the house

Rear patio, by the French doors

WHAT WAS SEEN

Water lies on the patio or path, or the surface appears to fall towards the building.

REQUESTED ACTION · GROUNDWORKS, PAVING AND LANDSCAPING

Investigate the falls and drainage and correct them.

Status: Open · Recorded 22 Sept 2026, 23:20



Photo 1 · 22 Sept 2026, 23:20

What was checked

The route was built from the buyer's description of the home. This shows how each part was answered, so the reader can see what was not looked at as well as what was.

	Checks	Fine	Issue	N/A	Not done
Get things running	2	2	0	0	0
Outside: arriving	4	4	0	0	0
Hallway	7	5	2	0	0
Living room	7	6	1	0	0
Kitchen	11	10	1	0	0
Downstairs WC	7	7	0	0	0
Stairs	4	4	0	0	0
Landing	6	6	0	0	0
Main bedroom	6	6	0	0	0
Bedroom 2	6	6	0	0	0
Bedroom 3	6	6	0	0	0
En-suite	8	8	0	0	0
Bathroom	8	8	0	0	0
Loft	3	3	0	0	0
Heating, hot water and safety	3	3	0	0	0
Outside: around the home	10	9	1	0	0
Total	98	93	5	0	0

TOPICS LOOKED AT

For reference, the buyer's check touched 30 of 35 topics that appear in the NHQB pre-completion inspection checklists for this type of home. HOME by EYASTRA is independent. It is not produced, endorsed or approved by NHQB, the National House Building Council or any developer. Where this report refers to topics in the NHQB pre-completion inspection checklists, it does so only to show which topics the buyer's visual check looked at. It does not reproduce those checklists.

Looked at	Walls and ceilings	Looked at	Room-by-room finish check
Looked at	Floors	Looked at	Site safety, scaffolding, roads and tidiness
Looked at	Loft space	Looked at	Brickwork, render, cladding, damp-proof cours...
Looked at	Windows and glazing	Looked at	Chimneys
Looked at	Skirtings, stairs and handrails	Looked at	Roof, fascias, soffits and flashings (from the gr...
Looked at	Doors, including fire doors	Looked at	Gutters, downpipes and water butts
Looked at	Fitted joinery: cupboards, wardrobes, drawers,...	Not looked at	Balconies
Looked at	Tiling and sealant in wet areas	Not looked at	Porches and conservatories
Looked at	Baths, showers, basins, taps, WCs and towel r...	Looked at	Garages and parking
Looked at	Lighting	Looked at	Paths, driveways, edgings, lawns and steps
Looked at	Sockets, switches and visible wiring	Looked at	Drains and inspection chambers
Looked at	Consumer unit	Looked at	External vents and flues
Looked at	Ventilation	Looked at	External windows and doors
Looked at	Heating, boiler and radiators	Looked at	Outside taps, lights, meter boxes and pipes
Looked at	Hot and cold water tanks	Not looked at	Sheds, bin stores and bike stores
Looked at	Smoke, heat and carbon monoxide alarms	Looked at	Fences, walls and gates
Not looked at	Security alarm, doorbell and entry phone	Not looked at	Heat pumps and solar panels
Looked at	Appliances		